



中国国家强制性产品认证证书

证书编号: 2010010301407468

委托人名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

生产者(制造商)名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

生产企业名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

产品名称和系列、规格、型号

低压抽出式开关柜(低压成套开关设备)

GCS 主母线: $I_n A=4000A \sim 1600A$, $I_{cw}=80kA$; 配电母线: $I_n C=1000A \sim 400A$, $I_{cw}=30kA$; $U_e=380V$, $U_i=660V$; 50Hz; IP40

产品标准和技术要求

GB 7251.12-2013

上述产品符合强制性产品认证实施规则

CNCA-C03-01: 2014的要求, 特发此证。

发证日期: 2017年04月26日

有效期至: 2021年03月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2010年05月18日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主 任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1673454



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2010010301407468

NAME AND ADDRESS OF THE APPLICANT

NAN YA ELECTRIC(NAN TONG)CO.LTD
88, OUTER RING ROAD(E)CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY , JIANGSU, CHINA

NAME AND ADDRESS OF THE MANUFACTURER

NAN YA ELECTRIC(NAN TONG)CO.LTD
88, OUTER RING ROAD(E)CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY , JIANGSU, CHINA

NAME AND ADDRESS OF THE FACTORY

NAN YA ELECTRIC(NAN TONG)CO.LTD
88, OUTER RING ROAD(E)CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY , JIANGSU, CHINA

NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies

GCS 主母线:InA=4000A~1600A, Icw=80kA; 配电母线:Inc=1000A~
400A, Icw=30kA; Ue=380V, Ui=660V; 50Hz; IP40

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 7251.12-2013

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-01:2014).

Date of issue: Apr. 26, 2017 Date of expiry: Mar. 16, 2021

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: May. 18, 2010

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1673454