



中国国家强制性产品认证证书

证书编号: 2003010301059962

委托人名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

生产者(制造商)名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

生产企业名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

产品名称和系列、规格、型号

低压固定式开关柜 (低压成套开关设备)

GGD2 主母线: $I_n=1500A \sim 400A$, $I_{cw}=30kA$; $U_e=380V$, $U_i=380V$; 50Hz; IP30

产品标准和技术要求

GB 7251.12-2013

上述产品符合强制性产品认证实施规则
CNCA-C03-01: 2014的要求, 特发此证。

发证日期: 2017年04月26日

有效期至: 2019年11月25日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年07月14日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

中国质量认证中心



中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

Q 1673461



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010301059962

NAME AND ADDRESS OF THE APPLICANT

NAN YA ELECTRIC (NAN TONG) CO. LTD
88, OUTER RING ROAD (E) CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY, JIANGSU, CHINA

NAME AND ADDRESS OF THE MANUFACTURER

NAN YA ELECTRIC (NAN TONG) CO. LTD
88, OUTER RING ROAD (E) CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY, JIANGSU, CHINA

NAME AND ADDRESS OF THE FACTORY

NAN YA ELECTRIC (NAN TONG) CO. LTD
88, OUTER RING ROAD (E) CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY, JIANGSU, CHINA

NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies

GGD2 主母线: $I_n=1500A \sim 400A$, $I_{cw}=30kA$; $U_e=380A$, $U_i=380V$; 50Hz; IP30

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 7251.12-2013

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-01:2014).

Date of issue: Apr. 26, 2017 Date of expiry: Nov. 25, 2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jul. 14, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1673461