



中国国家强制性产品认证证书

证书编号: 2003010301091578

委托人名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

生产者(制造商)名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

生产企业名称、地址

南亚电气(南通)有限公司
江苏南通市通京大道88号

产品名称和系列、规格、型号

低压动力分电柜(低压成套开关设备)

MB200 主母线: InA=5000A、4000A~1600A, Icw=65kA; 配电母线: Inc=1000A~800A, Icw=65kA; Ue=380V, Ui=690V; 50Hz; IP30

产品标准和技术要求

GB 7251.12-2013

上述产品符合强制性产品认证实施规则
CNCA-C03-01: 2014的要求, 特发此证。

发证日期: 2017年04月26日

有效期至: 2019年11月04日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年10月29日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1673444



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010301091578

NAME AND ADDRESS OF THE APPLICANT

NAN YA ELECTRIC(NAN TONG) CO. LTD
88, OUTER RING ROAD(E)CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY , JIANGSU, CHINA

NAME AND ADDRESS OF THE MANUFACTURER

NAN YA ELECTRIC(NAN TONG) CO. LTD
88, OUTER RING ROAD(E)CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY , JIANGSU, CHINA

NAME AND ADDRESS OF THE FACTORY

NAN YA ELECTRIC (NAN TONG) CO. LTD
88, OUTER RING ROAD(E)CHONGCHUAN DEVELOPMENT ZONE NANTONG
CITY , JIANGSU, CHINA

NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies

MB200 主母线:InA=5000A、4000A~1600A, Icw=65kA; 配电母线:Inc=1000A~
800A, Icw=65kA;Ue=380V, Ui=690V;50Hz;IP30

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 7251.12-2013

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-01:2014).

Date of issue: Apr. 26, 2017 Date of expiry: Nov. 04, 2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Oct. 29, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q. 1673444